

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015839.07
DATE: 01/02/2024
CERTIFICATION PROGRAM: Structural
COMPANY: YKK AP America
CODE: 860-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
YKK AP America, Inc. 101 Marietta Street NW, Suite 2100 Atlanta, GA 30303	StyleView® Classic Twin Single Hung Vinyl Window Configuration: O/XO/X Glazing: Insulating Glass (Annealed) Frame: W-2019mm(79.5") H-1867mm(73.5") Sash: W-933mm(36.72") H-900mm(35.44") DLO: W-847mm(33.34") H-840mm(33.06")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class R-PG35 2032 x 1880 (80 x 74)-H Design Pressure: ±1680 Pa (±35 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.50 psf)

Product Tested By: Intertek, PLC
Report No: P5942.05-550-44/W-2110
Expiration Date: **January 31, 2028**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com

NOPC 03/30/2023