

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015839.12  
DATE: 08/03/2023  
CERTIFICATION PROGRAM: Structural  
COMPANY: YKK AP America  
CODE: 860-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>YKK AP America, Inc.</b> <b>101 Marietta Street NW, Suite 2100</b> <b>Atlanta, GA 30303</b>	<b>StyleView® Classic</b> <b>Cottage Single Hung Vinyl Window</b>  Configuration: O/X Glazing: Insulating Glass (Annealed)  Frame: W-1118mm(43.5") H-2019mm(79.5") Sash: W-1061mm(41.78") H-1184mm(46.62")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b>	<b>Class R-PG35 1118 x 2032 (44 x 80)-H</b> <b>Design Pressure: ±1680 Pa (±35 psf)</b> <b>Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf)</b>

Product Tested By: Intertek, PLC  
Report No: P5942.03-550-44/W-2111  
Expiration Date: January 31, 2028

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "Shi D".

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023