

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015839.14-R1  
**DATE:** 01/02/2024  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** YKK AP America  
**CODE:** 860-1  
**REVISION DATE:** 04/18/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>YKK AP America, Inc.</b> <b>101 Marietta Street NW, Suite 2100</b> <b>Atlanta, GA 30303</b>	<b>StyleView® Classic</b> <b>Cottage Single Hung Vinyl Window</b>  Configuration: O/X Glazing: Insulating Glass (Annealed)  Frame: W-1003mm(39.5") H-1918mm(75.5") Sash: W-960mm(37.78") H-1141mm(44.23")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b>	<b>Class R-PG50 1003 x 1918 (40 x 76)-H</b> <b>Design Pressure: ±2400 Pa (±50 psf)</b> Water Penetration Resistance Test Pressure: 360 Pa (7.50 psf)

Product Tested By: Intertek, PLC  
Report No: Q1858.01-550-44/P5942.01-550-44/W-2111/W-2119  
Expiration Date: **January 31, 2028**

A handwritten signature in black ink, appearing to be "S.M.", written over a horizontal line.

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Email: [nami@namiinc.com](mailto:nami@namiinc.com)