NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO:
DATE:
CERTIFICATION PROGRAM:
COMPANY:
CODE:

DTITICATI

NI015946.02
01/02/2024
Structural
Ptek Windows
2251-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com</u>. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION	
Ptek Windows SA de CV	Series "700PW"	
Calle campo 2-B, #76, Campo Número 2-B	Vinyl Fixed Picture Window	
Cd. Cuauhtémoc, Chih. C.P. 31604	(New Construction Frame)	
	Configuration: O Glazing: Insulating Glass (Annealed)	
	Frame: W-1524mm(60") H-1524mm(60")	
	DLO: W-1359mm(53.50") H-1359mm(53.50")	

SPECIFICATION		PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08		Class LC-PG40 1524 x 1524 (60 x 60)-FW Design Pressure: ±1920 Pa (±40 psf) Water Penetration Resistance Pressure: 510 Pa (10.66 psf)
Product Tested By:	Intertek, PLC	•
Penart No:	10130 08 501 44	

Report No: Expiration Date: Intertex, FLC I9139.08-501-44 January 31, 2028

Shi

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC 03/30/2023