

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015946.03
DATE: 01/02/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Ptek Windows
CODE: 2251-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|--|--|
| Ptek Windows SA de CV Calle campo 2-B, #76, Campo Número 2-B Cd. Cuauhtémoc, Chih. C.P. 31604 | Series "700PW" Vinyl Fixed Picture Window (Replacement Frame) Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-1524mm(60") H-1524mm(60") DLO: W-1359mm(53.50") H-1359mm(53.50") |

| SPECIFICATION | PRODUCT RATING |
|--|---|
| AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 | Class LC-PG55 1524 x 1524 (60 x 60)-FW Design Pressure: ±2640 Pa (±55 psf) Water Penetration Resistance Pressure: 510 Pa (10.66 psf) |

Product Tested By: Intertek, PLC
Report No: I9139.08-501-44
Expiration Date: **January 31, 2028**

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com