

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015947
DATE: 01/02/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Ptek Windows
CODE: 2251-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ptek Windows SA de CV Calle campo 2-B, #76, Campo Número 2-B Cd. Cuauhtémoc, Chih. C.P. 31604	Series "700CA" Vinyl Swing-Out Casement Window (New Construction Frame 730 CS-T000) Configuration: X Glazing: Insulating Glass (Annealed) Frame: W-914mm(36") H-1829mm(72") Vent: W-867mm(34.13") H-1781mm(70.13") DLO: W-752mm(29.63") H-1667mm(65.63")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class LC-PG50 914 x 1829 (36 x 72)-C Design Pressure: 2400 Pa (50 psf) Positive Design Pressure: 2640 Pa (55 psf) Negative Design Pressure: 2400 Pa (50 psf) Water Penetration Resistance Pressure: 440 Pa (9.19 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Intertek, PLC
Report No: I2923.18-501-44
Expiration Date: **January 31, 2028**

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com