

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015957
DATE: 01/16/2024
CERTIFICATION PROGRAM: Fire
COMPANY: Bjornstad Const.
CODE: 2644-1
EXPIRATION DATE: 01/31/2028

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Bjornstad Construction Company 1240 Texan Trail, Suite 102 Grapevine, TX 76051	Lynden 20 Minute Profiled Particleboard Core Fire Door Assembly Manufacturer Specific Fire Doors for Single and Double Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw for Singles 3-Point Latching Hardware Required for Doubles Single & Double Swing Only Single Maximum Size: 3'0" x 8'0" Single Maximum Size: 3'6" x 7'0" Double Maximum Size: 6'0" x 7'0" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
NFPA 252 (2008)(2012) UL 10C (2001)(2009) UL 10B (2008)(2009) UBC Standard 7-2 (1997) CAN/ULC S104 (1980 (R1985))	20 Minute-Positive Pressure With Hose Stream Category B Door-Additional Edge Seal Required (unless specified in individual manufacturer's listing) For Use in ANSI-A155/UL-63 16-Gauge Steel Frame (or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)
TEST REPORT	
Intertek Test Report No: 3141706COQ-001	

Administrator's Signature: 

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com