NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015959

DATE: 01/16/2024

CERTIFICATION PROGRAM: Fire

COMPANY: Bjornstad Const.

CODE: <u>2644-1</u>

EXPIRATION DATE: 01/31/2028

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Bjornstad Construction Company	Lynden 20 Minute L20SP
1240 Texan Trail, Suite 102	Wood Core Fire Door Assembly
Grapevine, TX 76051	Manufacturer Specific Fire Doors for Single and Double Swing Installation in 20 Minute Locations
	1/2" Minimum Latch Throw for Singles 3/4" Minimum Latch Throw for Double Single & Double Swing Only
	Single Maximum Size: 4'0" x 9'0" Single Maximum Size: 3'6" x 10'0" Double Maximum Size: 8'0" x 9'0" Double Egress Maximum Size: 8'0" x 8'0" Dutch Door: 4'0" x 8'0" Door w/Transom Maximum Size: 4'0" x 10'0" Transom Maximum Size: 3'0" x 3'4" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
NFPA 252 (2008)(2012) UL 10C (2001)(2009)(2016) UL 10B (2008)(2009) UBC Standard 7-2 (1994)(1997)(2015) CAN/ULC S104 (1985)(2010) CSFM 43.7	20 Minute-Positive Pressure With Hose Stream Category B Door-Additional Edge Seal Required (unless specified in individual manufacturer's listing) For Use in Category C-Standard Frame (or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)

TEST REPORT

Intertek Test Report No: 491-7972/3052139/3060684/3075954/3157236/103140421

Administrator's Signature:



NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124

nami@namiinc.com