

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015961.01  
DATE: 01/16/2024  
CERTIFICATION PROGRAM: Structural  
COMPANY: ELICC  
CODE: 3009-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>ELICC Group</b> <b>13478 Danielson Street, Suite 250</b> <b>Poway, CA 92064</b>	<b>Series "Elicc CW-100"</b> <b>Aluminum Curtain Wall System</b>  Configuration: OOOOO/OOOOO Glazing: Laminate - 1/4" Heat Strengthened Glass/0.090" SGP Interlayer/1/4" Heat Strengthened Glass  Frame: W-6172mm(243") H-8039mm(316.5") DLO: W-1143mm(45") H-3385mm(133.25")

SPECIFICATION	PRODUCT RATING
<b>TAS 201/202/203-94</b>	<b>Design Pressure: ±3591 Pa (±75 psf)</b> <b>Water Penetration Resistance Test Pressure: 718 Pa (11.25 psf)</b> <b>Large Missile Impact Rated</b>

Product Tested By: Blackwater Technical Services, Inc.  
Report No: BT-ELG-22-002  
Expiration Date: September 30, 2027

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be 'S. D.', written over a horizontal line.

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

[nami@namiinc.com](mailto:nami@namiinc.com)

NOPC 03/30/2024