

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015962
DATE: 01/22/2024
CERTIFICATION PROGRAM: Structural
COMPANY: MAISON JAN
CODE: 2883-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Maison Janneau, LLC 5555 N Lamar Blvd., Suite L125 Austin, Texas 78751	Series "TRADI - LAFAYETTE and MGL - VERSAILLES" Wood Transom Window Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-2000mm(78.75") H-498mm(19.63") DLO: W-1883mm(74.13") H-381mm(15")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class R-PG60 2000 x 498 (79 x 20)-TR Design Pressure: ±2880 Pa (±60 psf) Water Penetration Resistance Test Pressure: 440 Pa (9.20 psf)

Product Tested By: Molimo, LLC
Report No: 12405.03-106-11
Expiration Date: **October 31, 2027**

Administrator's Signature:  _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com