

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015963  
**DATE:** 01/22/2024  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** MAISON JAN  
**CODE:** 2883-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Maison Janneau, LLC</b> <b>5555 N Lamar Blvd., Suite L125</b> <b>Austin, Texas 78751</b>	<b>Series "TRADI - LAFAYETTE</b> <b>Wood Awning Window</b>  Configuration: X Glazing: Insulating Glass (Annealed) Frame: W-1200mm(47.25") H-800mm(31.50") Vent: W-1149mm(45.25") H-743mm(29.25") DLO: W-1010mm(39.75") H-591mm(23.25")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b>	<b>Class R-PG60 1200 x 800 (47 x 32)-AP</b> <b>Design Pressure: ±2880 Pa (±60 psf)</b> Water Penetration Resistance Test Pressure: 440 Pa (9.20 psf)

Product Tested By: Molimo, LLC  
Report No: 12442.03-106-11  
Expiration Date: **October 31, 2027**

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)