

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015966
DATE: 01/24/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Wood On
CODE: 1332-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Wood On LLC dba MW Millworks 7225 Peppermill Parkway North Charleston, SC 29418	Series "Impact Rated Glazed Wood Doors" Inswing Glazed Wood Doors (w/Sidelites & Transom) Configuration: OXO/OXXO Glazing: IG:Ext.-1/4" Tempered Glass/3/16" Heat Strengthened Glass/0.090" Sentryglas Interlayer/3/16" Heat Strengthened Glass Frame: W-4597mm(181") H-4166mm(164") Panel: W-1067mm(42") H-3048mm(120") DLO: W-775mm(30.50") H-2273mm(89.50")

SPECIFICATION	PRODUCT RATING
ASTM E283-04 ASTM E330-14 ASTM E331-00 ASTM E1886-13a ASTM E1996-14a	Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf) Missile Level D Large Missile Impact Rated

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 06113750
Expiration Date: May 31, 2027

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023