

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015967.01
DATE: 01/25/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Soft-Lite
CODE: 2336-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Soft-Lite Windows 10250 Phillip Parkway Streetsboro, OH 44241	Series "Barcelona" Vinyl Fixed Window (PW30I) Configuration: O Glazing: IG: Ext.-1/4" Annealed Glass/Int.-1/8" Annealed Glass/0.090" SentryGlas PVB Interlayer/1/8" Annealed Glass Frame: W-1981mm(78") H-1829mm(72") DLO: W-1818mm(71.56") H-1691mm(66.56")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 ASTM E1886-13a ASTM E1996-14a TAS 201/202/203-94	Class R-PG50 1981 x 1829 (78 x 72)-FW Design Pressure: 2400 Pa (50 psf) Positive Design Pressure: 2880 Pa (60 psf) Negative Design Pressure: 3120 Pa (65 psf) Water Penetration resistance Test Pressure: 720 Pa (15.00 psf) Wind Zone 4 - Missile Level D Large Missile Impact Rated

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 03003321/TEL 03003322/TEL 03003323
Expiration Date: April 30, 2027

Administrator's Signature: 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023