

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015967  
**DATE:** 01/25/2024  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Soft-Lite  
**CODE:** 2336-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Soft-Lite Windows</b> <b>10250 Phillip Parkway</b> <b>Streetsboro, OH 44241</b>	<b>Series "Barcelona"</b> <b>Vinyl Fixed Window</b> <b>(PW30I)</b>  Configuration: O Glazing: IG: Ext.-1/4" Annealed Glass/Int.-1/8" Annealed Glass/0.090" SentryGlas PVB Interlayer/1/8" Annealed Glass  Frame: W-2438mm(96") H-1524mm(60")  DLO: W-2275mm(89.56") H-1360mm(53.56")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>ASTM E1886-13a</b> <b>ASTM E1996-14a</b> <b>TAS 201/202/203-94</b>	<b>Class R-PG60 2438 x 1524 (96 x 60)-FW</b> <b>Design Pressure: 2880 Pa (60 psf)</b> <b>Positive Design Pressure: 2880 Pa (60 psf)</b> <b>Negative Design Pressure: 3120 Pa (65 psf)</b> <b>Water Penetration resistance Test Pressure: 720 Pa (15.00 psf)</b> <b>Wind Zone 4 - Missile Level D</b> <b>Large Missile Impact Rated</b>

Product Tested By: Testing Evaluation Laboratories, Inc.  
Report No: TEL 03003321/TEL 03003322/TEL 03003323  
Expiration Date: April 30, 2027

Administrator's Signature: 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023