

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016000.02
DATE: 11/16/2023
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Custom Clad Epic Plus" Aluminum Clad Wood Awning Window Configuration: X Glazing: Insulating Glass (Annealed) Frame: W-536mm(21.13") H-1534mm(60.38") Vent: W-486mm(19.13") H-1475mm(58.06") DLO: W-379mm(14.94") H-1365mm(53.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11	Class LC-PG65 536 x 1534* (21 x 60*)-AP Design Pressure: ±3120 Pa (±65 psf) Water Penetration Resistance Test Pressure: 580 Pa (12.11 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: Intertek, PLC
Report No: I8215.01-301-47/I8188.01-301-47
Expiration Date: December 31, 2027

Administrator's Signature: 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com