NOTICE OF PRODUCT CERTIFICATION •



CERTIFICATION NO: NI016000

DATE: 11/16/2023

CERTIFICATION PROGRAM: Structural

COMPANY: <u>JELD-WEN</u>

CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN	Series "Custom Clad Epic Plus"
3737 Lakeport Boulevard	Aluminum Clad Wood Awning Window
Klamath Falls, OR 97601	
	Configuration: X Glazing: Insulating Glass (Annealed)
	Frame: W-1534mm(60.38") H-1534mm(60.38")
	Vent: W-1474mm(58.06") H-1474mm(58.06")
	DLO: W-1367mm(53.81") H-1365mm(53.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11	Class LC-PG35 1534 x 1534 (60 x 60)-AP Design Pressure: ±1680 Pa (±35 psf) Water Penetration Resistance Test Pressure: 260 Pa (5.25 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: Intertek, PLC
Report No: I8188.01-301-47
Expiration Date: December 31, 2027

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124

Email: nami@namiinc.com