NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: DATE: CERTIFICATION PROGRAM: COMPANY: CODE:

NI016001.02
11/21/2023
Structural
JELD-WEN
1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com</u>. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN	Series "EpicVue Clad"
3737 Lakeport Boulevard	Aluminum Clad Wood Awning Window
Klamath Falls, OR 97601	
	Configuration: X Glazing: Insulating Glass (Annealed)
	Frame: W-915mm(36.02") H-610mm(24.02")
	Vent: W-864mm(34.02") H-562mm(22.13")
	DLO: W-790mm(31.10") H-470mm(18.50")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09	Class CW-PG65 915 x 610* (36 x 24*)-AP Design Pressure: ±3120 Pa (±65 psf) Water Penetration Resistance Test Pressure: 580 Pa (12.11 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Report No: Expiration Date: National Certified Testing Laboratories SJW2015-086/SJW2015-084 December 31, 2027

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC. 4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124 Email: nami@namiinc.com

NOPC-03/30/2023