

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016002
DATE: 11/21/2023
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p>JELD-WEN</p> <p>3737 Lakeport Boulevard</p> <p>Klamath Falls, OR 97601</p>	<p style="text-align: center;">Series "Custom Clad Extruded Sash - IG Impact"</p> <p style="text-align: center;">Aluminum Clad Wood Awning Window</p> <p style="text-align: center;">Configuration: X Glazing: IG-Ext.-1/8" Annealed Glass/Int.-5/32" Annealed Glass/0.090" SGP Interlayer by Dupont/5/32" Annealed Glass OR Glazing: IG-Ext.-1/8" Tempered Glass/Int.-5/32" Annealed Glass/0.090" SGP Interlayer by Dupont/5/32" Annealed Glass</p> <p>Frame: W-1219mm(48") H-914mm(36")</p> <p>Vent: W-1172mm(46.13") H-864mm(34")</p> <p>DLO: W-1092mm(43") H-772mm(30.38")</p>

SPECIFICATION	PRODUCT RATING
<p>AAMA/WDMA/CSA 101/I.S.2/A440-11</p> <p>AAMA/WDMA/CSA 101/I.S.2/A440-08</p> <p style="text-align: center;">ASTM E1886-2004/05</p> <p style="text-align: center;">ASTM E1996-2002/04/06/09/12a</p>	<p style="text-align: center;">Class LC-PG50 1219 x 914 (48 x 36)-AP</p> <p style="text-align: center;">Design Pressure: 2400 Pa (50 psf)</p> <p style="text-align: center;">Positive Design Pressure: 2400 Pa (50 psf)</p> <p style="text-align: center;">Negative Design Pressure: 2880 Pa (60 psf)</p> <p style="text-align: center;">Water Penetration Resistance Test Pressure: 440 Pa (9.18 psf)</p> <p style="text-align: center;">Wind Zone 3 - Missile Level D</p>

Product Tested By: National Certified Testing Laboratories
 Report No: SJW2013-256
 Expiration Date: **December 31, 2027**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
 Email: nami@namiinc.com