

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016003.05
DATE: 11/21/2023
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Custom Wood - Rotary Operated Awning" Wood Awning Window Configuration: X Glazing: Insulating Glass (Annealed) Frame: W-914mm(36") H-610mm(24") Vent: W-865mm(34.06") H-560mm(22.06")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09	Class LC-PG65 914 x 610* (36 x 24*)-AP Design Pressure: ±3120 Pa (±65 psf) Water Penetration Resistance Test Pressure: 470 Pa (9.82 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: National Certified Testing Laboratories
Report No: SJW2013-181/SJW2013-179
Expiration Date: **December 31, 2027**

Administrator's Signature: 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com