

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016006.02
DATE: 11/21/2023
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Custom Clad - Casement Picture" Aluminum Clad Wood Fixed Window Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-1524mm(60") H-1829mm(72") Vent: W-1476mm(58.13") H-1781mm(70.13") DLO: W-1399mm(55.06") H-1688mm(66.50")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09	Class CW-PG65 1524 x 1829 (60 x 72)-FW Design Pressure: ±3120 Pa (±65 psf) Water Penetration Resistance Test Pressure: 470 Pa (9.82 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: National Certified Testing Laboratories
Report No: SJW2013-151
Expiration Date: December 31, 2027

Administrator's Signature: 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com