NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016007

DATE: 11/21/2023

CERTIFICATION PROGRAM: Structural

COMPANY: <u>JELD-WEN</u>

CODE: <u>1822-1</u>

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN	Series "Custom Clad - IG Impact"
3737 Lakeport Boulevard	Aluminum Clad Wood Fixed Window
Klamath Falls, OR 97601	Insash Geometric
	(w/Nail Fin, Through Frame, Masonry Strap)
	Configuration: O Glazing: IG-Ext. 5/32" Annealed Glass/1/8" Annealed Glass/0.090" SentryGlas Kuraray Interlayer/1/8" Annealed Glass
	Frame: W-1525mm(60.12") H-1830mm(72.05")
	Vent: W-1475mm(58.07") H-1780mm(70.08")
	DLO: W-1395mm(54.92") H-1685mm(66.34")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 ASTM E1886-13a ASTM E1996-14a/17	Class LC-PG60 1525 x 1830 (60 x 72)-FW Design Pressure: 2880 Pa (60 psf) Positive Design Pressure: 2880 Pa (60 psf) Negative Design Pressure: 3120 Pa (65 psf)
	Water Penetration Resistance Test Pressure: 440 Pa (9.19 psf) Wind Zone 3 - Missile Level D

Product Tested By: National Certified Testing Laboratories Report No: NCTL-310-18-026/J4261.01-301-47

Expiration Date: **December 31, 2027**

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124

Email: nami@namiinc.com

NOP C-03/30/2023