

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO:	<u>NI016008.02</u>
DATE:	<u>11/27/2023</u>
CERTIFICATION PROGRAM:	<u>Structural</u>
COMPANY:	<u>JELD-WEN</u>
CODE:	<u>1822-1</u>

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p>JELD-WEN</p> <p>3737 Lakeport Boulevard</p> <p>Klamath Falls, OR 97601</p>	<p>Series "Custom Clad"</p> <p>Aluminum Clad Wood Casement</p> <p>Picture Window</p> <p>(w/Nail Fin, Through-Frame, Masonry Straps)</p> <p>Configuration: O Glazing: IG-Ext.- 3/16" Annealed Glass/Int.-3/16" Annealed Glass/0.090" SGP by Kuraray Interlayer/3/16" Annealed Glass</p> <p>Frame: W-2133mm(84") H-1829mm(72")</p> <p>Sash: W-2083mm(82") H-1781mm(70.13")</p> <p>DLO: W-2010mm(79.13") H-1689mm(66.50")</p>

SPECIFICATION	PRODUCT RATING
<p>AAMA/WDMA/CSA 101/I.S.2/A440-17</p> <p>AAMA/WDMA/CSA 101/I.S.2/A440-11</p> <p>ASTM E1886-13a</p> <p>ASTM E1996-17</p>	<p>Class LC-PG60 2133 x 1829 (84 x 72)-FW</p> <p>Design Pressure: 2880 Pa (60 psf)</p> <p>Positive Design Pressure: 2880 Pa (60 psf)</p> <p>Negative Design Pressure: 3120 Pa (65 psf)</p> <p>Water Penetration Resistance Test Pressure: 580 Pa (12.11 psf)</p> <p>Canadian Infiltration/Exfiltration Level: Fixed</p> <p>Wind Zone 3 - Missile Level D</p> <p>Large Missile Impact Rated</p>

Product Tested By: Intertek, PLC
 Report No: N0975.01-301-47
 Expiration Date: December 31, 2027

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124/Email: nami@namiinc.com