

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016008
DATE: 11/21/2023
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Custom Clad - IG Impact" Aluminum Clad Wood Casement Picture Window (w/Nail Fin, Through Frame, Masonry Strap) Configuration: O Glazing: IG-Ext. 3/16" Annealed Glass/1/8" Annealed Glass/0.090" SGP Interlayer/1/8" Annealed Glass Frame: W-1527mm(60.12") H-1833mm(72.17") Sash: W-1477mm(58.15") H-1782mm(70.16") DLO: W-1400mm(55.12") H-1690mm(66.54")

SPECIFICATION	PRODUCT RATING
ASTM E1886-05/13a ASTM E1996-09/12a/14a	Design Pressure: 2880 Pa (60 psf) Positive Design Pressure: 2880 Pa (60 psf) Negative Design Pressure: 3120 Pa (65 psf) Wind Zone 3 - Missile Level D

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-310-18-018
Expiration Date: **December 31, 2027**

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com