NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: DATE: CERTIFICATION PROGRAM: COMPANY: CODE:

NI016009.02	
11/27/2023	
Structural	
JELD-WEN	
1822-1	

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com</u>. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS]	PRODUCT DESC	CRIPTION
JELD-WEN	Se	eries "Custom Cla	d Epic Plus"
3737 Lakeport Boulevard	Alumin	um Clad Wood C	Casement Window
Klamath Falls, OR 97601			
		Configuratio Glazing: Insulating Gla	
	Frame: V	W-1428mm(56.25")	H-1629mm(64.13")
	Sash:	W-1372mm(54")	H-1575mm(62")
	DLO:	W-1269mm(49.94")	H-1469mm(57.81")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11	Class LC-PG50 1428 x 1629 (56 x 64)-C Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) Canadian Infiltration/Exfiltration Level: A3

Product Tested By:	Intertek, PLC
Report No:	I8252.01-301-47
Expiration Date:	December 31, 2027

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124 Email: nami@namiinc.com

NOPC-03/30/2023