NOTICE OF PRODUCT CERTIFICATION '



CERTIFICATION NO: NI016009.03

DATE: 11/27/2023

CERTIFICATION PROGRAM: <u>Structural</u>

COMPANY: <u>JELD-WEN</u>

CODE: <u>1822-1</u>

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN	Series "Custom Clad Epic Plus"
3737 Lakeport Boulevard	Aluminum Clad Wood Casement Window
Klamath Falls, OR 97601	
	Configuration: X Glazing: Insulating Glass (Annealed)
	Frame: W-1375mm(54.13") H-1678mm(66.13")
	Sash: W-1323mm(52.06") H-1626mm(64")
	DLO: W-1217mm(47.94") H-1519mm(59.81")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11	Class LC-PG50 1375 x 1678 (54 x 66)-C Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) Canadian Infiltration/Exfiltration Level: A2

Product Tested By: Intertek, PLC
Report No: I8252.01-301-47
Expiration Date: December 31, 2027

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023