## NOTICE OF PRODUCT CERTIFICATION •



**CERTIFICATION NO:** NI016009.04

**DATE:** 11/27/2023

**CERTIFICATION PROGRAM:** Structural

**COMPANY:** <u>JELD-WEN</u>

CODE: <u>1822-1</u>

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <a href="www.namicertification.com">www.namicertification.com</a>. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION                                   |
|--------------------------|---|
| JELD-WEN                 | Series "Custom Clad Epic Plus"                        |
| 3737 Lakeport Boulevard  | Aluminum Clad Wood Casement Window                    |
| Klamath Falls, OR 97601  |   |
|                          | Configuration: X Glazing: Insulating Glass (Annealed) |
|                          | Frame: W-1220mm(48.06") H-2439mm(96")                 |
|                          | Sash: W-1171mm(46.13") H-2388mm(94")                  |
|                          | DLO: W-1065mm(41.94") H-2282mm(89.81")                |

| SPECIFICATION  | PRODUCT RATING   |
|--|--|
| AAMA/WDMA/CSA 101/I.S.2/A440-17<br>AAMA/WDMA/CSA 101/I.S.2/A440-11 | Class LC-PG50 1220 x 2439 (48 x 96)-C Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) Canadian Infiltration/Exfiltration Level: A2 |

Product Tested By: Intertek, PLC
Report No: I8254.01-301-47
Expiration Date: December 31, 2027

Administrator's Signature:

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124

Tel: (804) 684-5124 Email: nami@namiinc.com

NOPC-03/30/2023