

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016009.05
DATE: 11/27/2023
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Custom Clad Epic Plus" Aluminum Clad Wood Casement Window Configuration: X Glazing: Insulating Glass (Annealed) Frame: W-1067mm(42") H-1982mm(78.06") Sash: W-1019mm(40.13") H-1930mm(76") DLO: W-912mm(35.88") H-1825mm(71.88")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11	Class LC-PG60 1067 x 1982 (42 x 78)-C Design Pressure: 2880 Pa (60 psf) Positive Design Pressure: 3120 Pa (65 psf) Negative Design Pressure: 3120 Pa (65 psf) Water Penetration Resistance Test Pressure: 440 Pa (9.19 psf) Canadian Infiltration/Exfiltration Level: A2

Product Tested By: Intertek, PLC
Report No: I8254.01-301-47
Expiration Date: December 31, 2027

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com