

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016012
DATE: 11/28/2023
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Custom Wood - Push-Out French Casement - Stationary" Wood Casement Window Configuration: OO Glazing: Insulating Glass (Annealed) Frame: W-1422mm(56") H-1829mm(72") Sash: W-664mm(26.13") H-1781mm(70.13") DLO: W-552mm(21.75") H-1670mm(65.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 CSA A440S1-17	Class LC-PG35 1422 x 1829 (56 x 72)-FW Design Pressure: 1680 Pa (35 psf) Positive Design Pressure: 1680 Pa (35 psf) Negative Design Pressure: 1920 Pa (40 psf) Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf) Canadian Infiltration/Exfiltration Level: A3

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-310-19-147
Expiration Date: December 31, 2027

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com