NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016014.01

DATE: 11/28/2023

CERTIFICATION PROGRAM: Structural

COMPANY: <u>JELD-WEN</u>

CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN	Series "Custom Clad - IG Impact"
3737 Lakeport Boulevard	Aluminum Clad Wood Casement Window
Klamath Falls, OR 97601	(w/Dual Arm & Concealed Hinge)
	Configuration: X Glazing: IG-Ext1/8" Annealed Glass/Int1/8" Annealed Glass/0.090" SGP Interlayer by Dupont/1/8" Annealed Glass OR Glazing: IG-Ext1/8" Tempered Glass/Int5/32" Annealed Glass/0.090" SGP Interlayer by Dupont/5/32" Annealed Glass
	Frame: W-914mm(36") H-1829mm(72")
	Sash: W-864mm(34") H-1778mm(70")
	DLO: W-787mm(31") H-1689mm(66.50")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 ASTM E1886-04/05 ASTM E1996-02/04/06/09/12a	Class LC-PG50 914 x 1829 (36 x 72)-C Design Pressure: 2400 Pa (50 psf) Positive Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2880 Pa (60 psf) Water Penetration Resistance Test: 440 Pa (9.19 psf) Wind Zone 3 - Missile Level D Large Missile Impact Rated

Product Tested By: National Certified Testing Laboratories

Report No: SJW2013-254

Expiration Date: **December 31, 2027**

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023