

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016014.04
DATE: 11/28/2023
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Custom Clad" Aluminum Clad Wood Casement Windows Configuration: OOO/OOX Glazing: Insulating Glass (Annealed) Frame: W-1381mm(54.38") H-1219mm(48") Vent: W-460mm(18.13") H-765mm(30.13") DLO: W-330mm(13") H-616mm(24.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09 AAMA 450-06/10	Class LC-PG50 1381 x 1219* (54 x 48*)-FW Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test: 360 Pa (7.52 psf) Canadian Air Infiltration/Exfiltration Level: Fixed

Product Tested By: National Certified Testing Laboratories
Report No: SJW2014-016/SJW2013-151
Expiration Date: **December 31, 2027**

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023