NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016018.01

DATE: 11/28/2023

CERTIFICATION PROGRAM: Structural

COMPANY: <u>JELD-WEN</u>

CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN	Series "Custom Clad Sector Top"
3737 Lakeport Boulevard	Aluminum Clad Wood Rotary Operated
Klamath Falls, OR 97601	Casement Window
	Configuration: X Glazing: Insulating Glass (Annealed Glass)
	Frame: W-762mm(30") H-2134mm(84")
	Sash: W-713mm(28.06") H-2084mm(82.06")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09	Class R-PG65 762 x 2134 (30 x 84)-C Design Pressure: ±3120 Pa (±65 psf) Water Penetration Resistance Test: 470 Pa (9.82 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: National Certified Testing Laboratories

Report No: SJW2013-184
Expiration Date: **December 31, 2027**

Administrator's Signature: __

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023