

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016019.01
DATE: 11/28/2023
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series “Custom Wood - Pocket Casement” Wood Fixed Window Configuration: O Glazing: Insulating Glass (Annealed Glass) Frame: W-2156mm(84.88") H-1840mm(72.44") Sash: W-2084mm(82.06") H-1780mm(70.06") DLO: W-2008mm(79.06") H-1689mm(66.50")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09	Class CW-PG50 2156 x 1840 (85 x 72)-FW Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test: 360 Pa (7.52 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: National Certified Testing Laboratories
Report No: SJW2013-067
Expiration Date: December 31, 2027

Administrator's Signature:  _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023