

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016019.03  
DATE: 11/28/2023  
CERTIFICATION PROGRAM: Structural  
COMPANY: JELD-WEN  
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>JELD-WEN</b> <b>3737 Lakeport Boulevard</b> <b>Klamath Falls, OR 97601</b>	<b>Series "Custom Clad - Pocket Casement"</b> <b>Aluminum Clad Wood Fixed Window</b>  Configuration: O Glazing: Insulating Glass (Annealed Glass) Frame: W-1851mm(72.88") H-2145mm(84.44") Sash: W-1781mm(70.13") H-2086mm(82.13") DLO: W-1703mm(67.06") H-1994mm(78.50")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>CSA A440S1-09</b>	<b>Class CW-PG50 1851 x 2145 (73 x 84)-FW</b> <b>Design Pressure: ±2400 Pa (±50 psf)</b> <b>Water Penetration Resistance Test: 360 Pa (7.52 psf)</b> <b>Canadian Air Infiltration/Exfiltration Level: A3</b>

Product Tested By: National Certified Testing Laboratories  
Report No: SJW2013-069  
Expiration Date: December 31, 2027

Administrator's Signature:  \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023