

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016020  
DATE: 12/04/2023  
CERTIFICATION PROGRAM: Structural  
COMPANY: JELD-WEN  
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>JELD-WEN</b> <b>3737 Lakeport Boulevard</b> <b>Klamath Falls, OR 97601</b>	<b>Series "Custom Wood Insash Geometric Casement Sector Top"</b> <b>Wood Casement Window</b> <b>(w/Thru-Frame &amp; Masonry Strap)</b>  Configuration: X Glazing: Insulating Glass (Annealed Glass)  Frame: W-765mm(30.13") H-2134mm(84") Sash: W-716mm(28.19") H-2083mm(82") DLO: W-638mm(25.13") H-1992mm(78.44")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b>	<b>Class LC -PG65 765 x 2134 (30 x 84)-C</b> <b>Design Pressure: ±3120 Pa (±65 psf)</b> <b>Water Penetration Resistance Test: 470 Pa (9.82 psf)</b>

Product Tested By: Intertek, PLC  
Report No: K1127.01-301-47  
Expiration Date: **December 31, 2027**

Administrator's Signature: \_\_\_\_\_ 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023