

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016021
DATE: 12/12/2023
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Custom Clad Wide Gliding Door" Aluminum Clad Wood Fixed Door Configuration: X Glazing: IG-Ext.-5/32" Tempered Glass/1/8" Annealed Glass/0.090" Interlayer/1/8" Annealed Glass Frame: W-1430mm(56.31") H-2503mm(98.56") Panel: W-1367mm(53.81") H-2465mm(97.06") DLO: W-1045mm(41.13") H-2126mm(83.69")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11	Class LC -PG50 1430 x 2503 (53 x 99)-FD Design Pressure: 2400 Pa (50 psf) Positive Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2640 Pa (55 psf) Water Penetration Resistance Test: 360 Pa (7.52 psf)

Product Tested By: Intertek, PLC
Report No: I6805.01-301-47
Expiration Date: December 31, 2027

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023