

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016023  
DATE: 12/12/2023  
CERTIFICATION PROGRAM: Structural  
COMPANY: JELD-WEN  
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS  | PRODUCT DESCRIPTION  |
|---|--|
| <b>JELD-WEN</b><br><b>3737 Lakeport Boulevard</b><br><b>Klamath Falls, OR 97601</b> | <b>Series "Custom Clad Wide Stile"</b><br><b>Aluminum Clad Wood Fixed Door</b><br><b>(w/Nail Fin, Thru-Frame, Masonry Strap)</b><br><br>Configuration: O<br>Glazing: Insulating Glass (Tempered)<br>Frame: W-1345mm(52.94") H-2507mm(98.69")<br>Panel: W-1280mm(50.38") H-2418mm(95.19")<br>DLO: W-1046mm(41.19") H-2132mm(83.94") |

| SPECIFICATION  | PRODUCT RATING   |
|--|--|
| <b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b><br><b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b><br><b>CSA A440S1-17</b> | <b>Class LC -PG50 1345 x 2507 (53 x 99)-FD</b><br><b>Design Pressure: 2400 Pa (50 psf)</b><br><b>Positive Design Pressure: 2400 Pa (50 psf)</b><br><b>Negative Design Pressure: 2640 Pa (55 psf)</b><br>Water Penetration Resistance Test: 360 Pa (7.52 psf)<br>Canadian Air Infiltration/Exfiltration Level: A2 |

Product Tested By: Intertek, PLC  
Report No: J6414.01-301-47  
Expiration Date: **December 31, 2027**

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023