

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016024.01
DATE: 12/12/2023
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Custom Clad Wide Stile" Aluminum Clad Wood Sliding Door (w/Nail Fin, Thru-Frame, Masonry Strap) Configuration: OXO Glazing: Insulating Glass (Tempered) Frame: W-3820mm(150.38") H-2505mm(98.63") Panel: W-1284mm(50.56") H-2418mm(95.19") DLO: W-1048mm(41.25") H-2130mm(83.88")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11	Class LC -PG40 3820 x 2505 (150 x 99)-SD Design Pressure: ±1920 Pa (±40 psf) Water Penetration Resistance Test: 290 Pa (6.06 psf) Canadian Infiltration/Exfiltration Level: A3

Product Tested By: Intertek, PLC
Report No: J7467.01-301-47
Expiration Date: **December 31, 2027**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023