## NOTICE OF PRODUCT CERTIFICATION '



**CERTIFICATION NO:** NI016024

**DATE:** 12/12/2023

CERTIFICATION PROGRAM: <u>Structural</u>

**COMPANY:** <u>JELD-WEN</u>

**CODE:** 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <a href="www.namicertification.com">www.namicertification.com</a>. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN	Series "Custom Clad Wide Stile"
3737 Lakeport Boulevard	Aluminum Clad Wood Sliding Door
Klamath Falls, OR 97601	(w/Nail Fin, Thru-Frame, Masonry Strap)
	Configuration: OX Glazing: Insulating Glass (Tempered)
	Frame: W-2508mm(98.75") H-2503mm(98.56")
	Panel: W-1281mm(50.44") H-2418mm(95.19")
	DLO: W-1048mm(41.25") H-2130mm(83.88")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11	Class LC -PG50 2508 x 2503 (99 x 99)-SD Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test: 360 Pa (7.52 psf)

Product Tested By: Intertek, PLC
Report No: J7405.01-301-47
Expiration Date: **December 31, 2027** 

Administrator's Signature:

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124

Email: nami@namiinc.com NOP C-03/30/2023