

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016025.02
DATE: 12/12/2023
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Custom Clad Direct Set Monolithic Impact" Aluminum Clad Wood Fixed Window (w/Nail Fin, Thru-Frame, Masonry Strap) Configuration: O Glazing: Monolithic-3/16" Annealed Glass/0.090" SGP by Kuraray Interlayer/3/16" Annealed Glass Frame: W-2438mm(96") H-1829mm(72") DLO: W-2350mm(92.50") H-1734mm(68.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 ASTM E1886-13a ASTM E1996-17	Class LC-PG60 2438 x 1829 (96 x 72)-FW Design Pressure: 2880 Pa (60 psf) Positive Design Pressure: 2880 Pa (60 psf) Negative Design Pressure: 3120 Pa (65 psf) Water Penetration Resistance Test: 580 Pa (12.11 psf) Canadian Infiltration/Exfiltration Level: Fixed Wind Zone 3 - Missile Level D

Product Tested By: Intertek, PLC
Report No: N1009.01-301-47
Expiration Date: December 31, 2027

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023

