

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016026.03
DATE: 12/13/2023
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "EpicVue Clad Direct Set Geometric" Aluminum Clad Wood Fixed Window Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-3048mm(120") H-2134mm(84") DLO: W-2953mm(116.25") H-2039mm(80.28")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09	Class LC-PG50 3048 x 2134 (120 x 84)-FW Design Pressure: 2400 Pa (50 psf) Positive Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2640 Pa (55 psf) Water Penetration Resistance Test: 580 Pa (12.11 psf) Canadian Infiltration/Exfiltration Level: A3

Product Tested By: National Certified Testing Laboratories
Report No: SJW2016-054
Expiration Date: December 31, 2027

Administrator's Signature: 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023