

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016027.04  
DATE: 12/13/2023  
CERTIFICATION PROGRAM: Structural  
COMPANY: JELD-WEN  
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS  | PRODUCT DESCRIPTION   |
|---|---|
| <b>JELD-WEN</b><br><b>3737 Lakeport Boulevard</b><br><b>Klamath Falls, OR 97601</b> | <b>Series "Custom Wood Direct Set</b><br><b>Geometric Picture</b><br><b>Wood Fixed Window</b><br><br>Configuration: O<br>Glazing: Monolithic Glass (Annealed)<br><br>Frame: W-2134mm(84") H-2134mm(84")<br>DLO: W-2045mm(80.50") H-2045mm(80.50") |

| SPECIFICATION  | PRODUCT RATING   |
|--|--|
| <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b><br><b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b><br><b>CSA A440S1-09</b> | <b>Class CW-PG50 2134 x 2134 (84 x 84)-FW</b><br><b>Design Pressure: ±2400 Pa (±50 psf)</b><br><b>Water Penetration Resistance Test: 360 Pa (7.52 psf)</b><br><b>Canadian Infiltration/Exfiltration Level: Fixed</b> |

Product Tested By: National Certified Testing Laboratories  
Report No: SJW2013-182  
Expiration Date: **December 31, 2027**

Administrator's Signature: \_\_\_\_\_ 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023