

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016028.01  
DATE: 12/13/2023  
CERTIFICATION PROGRAM: Structural  
COMPANY: JELD-WEN  
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>JELD-WEN</b> <b>3737 Lakeport Boulevard</b> <b>Klamath Falls, OR 97601</b>	<b>Series "Custom Wood"</b> <b>Wood Double Hung Fixed Window</b>  Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-1965mm(77.36") H-2335mm(91.93") Sash: W-1914mm(75.36") H-2259mm(88.93") DLO: W-1814mm(71.42") H-2145mm(84.45")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>CSA A440S1-17</b>	<b>Class LC-PG35 1965 x 2335 (77 x 92)-FW</b> <b>Design Pressure: 1680 Pa (35 psf)</b> <b>Positive Design Pressure: 1680 Pa (35 psf)</b> <b>Negative Design Pressure: 1920 Pa (40 psf)</b> Water Penetration Resistance Test: 360 Pa (7.52 psf) Canadian Infiltration/Exfiltration Level: A3

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-17-064  
Expiration Date: **December 31, 2027**

Administrator's Signature: \_\_\_\_\_ 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023