NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: DATE: CERTIFICATION PROGRAM: COMPANY: CODE:

NI016028.02	
12/13/2023	
Structural	
JELD-WEN	
1822-1	

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com</u>. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION	
JELD-WEN	Series "Custom Clad Double Hung Picture"	
3737 Lakeport Boulevard	Aluminum Clad Wood	
Klamath Falls, OR 97601	Double Hung Fixed Window	
	Configuration: O Glazing: Insulating Glass (Annealed)	
	Frame: W-1254mm(49.38") H-1727mm(68")	
	Sash: W-1205mm(47.44") H-1657mm(65.25")	
	DLO: W-1103mm(43.44") H-1535mm(60.44")	

SPECIFICATION		PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09		Class LC-PG50 1254 x 1727* (49 x 68*)-FW Design Pressure: 2400 Pa (50 psf) Positive Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2640 Pa (55 psf) Water Penetration Resistance Test: 360 Pa (7.52 psf) Canadian Infiltration/Exfiltration Level: A3
Product Tested By: Report No: Expiration Date:	Element Materials Technology ESP025213P-2148-10/ESP025213P-2148.22 December 31, 2027	

Sh

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072 Tel: (804) 684-5124

Email: <u>nami@namiinc.com</u>

NOP C-03/30/2023