

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016028
DATE: 12/13/2023
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Custom Clad Double Hung Picture" Aluminum Clad Wood Double Hung Fixed Window Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-1965mm(77.38") H-2337mm(92") Sash: W-1918mm(75.50") H-2264mm(89.13") DLO: W-1815mm(71.44") H-2145mm(84.44")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09	Class LC-PG35 1965 x 2337 (77 x 92)-FW Design Pressure: 1680 Pa (35 psf) Positive Design Pressure: 1680 Pa (35 psf) Negative Design Pressure: 1920 Pa (40 psf) Water Penetration Resistance Test: 260 Pa (5.43 psf) Canadian Infiltration/Exfiltration Level: A3

Product Tested By: Element Materials Technology
Report No: ESP025213P-2148.22
Expiration Date: **December 31, 2027**

Administrator's Signature: 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023