

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016030.04  
DATE: 12/13/2023  
CERTIFICATION PROGRAM: Structural  
COMPANY: JELD-WEN  
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>JELD-WEN</b> <b>3737 Lakeport Boulevard</b> <b>Klamath Falls, OR 97601</b>	<b>Series "Custom Wood Epic Double Hung"</b> <b>Wood Double Hung Window</b>  Configuration: X/X Glazing: Insulating Glass (Annealed)  Frame: W-1321mm(52") H-3048mm(120") Sash: W-1200mm(47.25") H-1530mm(60.25") DLO: W-1067mm(42") H-1365mm(53.75")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Class LC-PG45 1321 x 3048 (52 x 120)-H</b> <b>Design Pressure: ±2160 Pa (±45 psf)</b> <b>Water Penetration Resistance Test: 330 Pa (6.89 psf)</b>

Product Tested By: National Certified Testing Laboratories  
Report No: SJW2013-219  
Expiration Date: **December 31, 2027**

Administrator's Signature:  \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023