NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: DATE: CERTIFICATION PROGRAM: COMPANY: CODE:

NI016030.07	
12/13/2023	
Structural	
JELD-WEN	
1822-1	

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com</u>. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION	
JELD-WEN	Series "Custom Clad Epic Double Hung"	
3737 Lakeport Boulevard	Aluminum Clad Wood Fixed Window	
Klamath Falls, OR 97601		
	Configuration: O Glazing: Insulating Glass (Annealed)	
	Frame: W-1732mm(68.19") H-2675mm(105.31")	
	Sash: W-1613mm(63.50") H-2575mm(101.38")	
	DLO: W-1483mm(58.38") H-2405mm(94.69")	

SPECIFICATION		PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09		Class CW-PG50 1732 x 2675 (68 x 105)-FW Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test: 480 Pa (10.03 psf) Canadian Air Infiltration/Exfiltration Level: Fixed
Product Tested By: National Certified Testing Laboratories		
Report No:	SJW2013-190	
Expiration Date:	December 31, 2027	

She

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124 Email: nami@namiinc.com

NOP C-03/30/2023