

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016030
DATE: 12/13/2023
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Custom Clad Epic Double Hung" Aluminum Clad Wood Double Hung Window Configuration: X/X Glazing: Insulating Glass (Annealed) Frame: W-1524mm(60") H-2545mm(100.19") Sash: W-1408mm(55.44") H-1273mm(50.13") DLO: W-1275mm(50.19") H-1111mm(43.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09	Class CW-PG50 1524 x 2545 (60 x 100)-H Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test: 360 Pa (7.52 psf) Canadian Infiltration/Exfiltration Level: A3

Product Tested By: National Certified Testing Laboratories
Report No: SJW2013-192
Expiration Date: **December 31, 2027**

Administrator's Signature: 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023