

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016031.01
DATE: 12/13/2023
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Custom Clad Double Hung" Aluminum Clad Wood Double Hung Window Configuration: X/X Glazing: IG-Ext.-1/8" Annealed Glass/Int.-1/8" Annealed Glass/0.090" PVB by Dupont Interlayer/1/8" Annealed Glass Frame: W-1054mm(41.50") H-1930mm(76") Sash: W-978mm(38.50") H-965mm(38") DLO: W-899mm(35.38") H-845mm(33.25")

SPECIFICATION	PRODUCT RATING
ASTM E1886-13a ASTM E1996-17	Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test: 360 Pa (7.52 psf) Wind Zone 3 - Missile Level D

Product Tested By: Intertek, PLC
Report No: M4128.01-301-47
Expiration Date: **December 31, 2027**

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023