

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI016032.09  
**DATE:** 12/14/2023  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** JELD-WEN  
**CODE:** 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>JELD-WEN</b> <b>3737 Lakeport Boulevard</b> <b>Klamath Falls, OR 97601</b>	<b>Series "Custom Wood"</b> <b>Wood Tilt Double Hung Window</b>  Configuration: X/X Glazing: Monolithic Glass (Annealed) Frame: W-1255mm(49.91") H-1932mm(76.06") Sash: W-1180mm(46.46") H-956mm(37.64") DLO: W-1105mm(43.50") H-850mm(33.46")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b>	<b>Class LC-PG35 1255 x 1932 (49 x 76)-H</b> <b>Design Pressure: 1680 Pa (35 psf)</b> <b>Positive Design Pressure: 1680 Pa (35 psf)</b> <b>Negative Design Pressure: 1920 Pa (40 psf)</b> <b>Water Penetration Resistance Test: 260 Pa (5.43 psf)</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-17-075/NCTL-110-17-068  
Expiration Date: December 31, 2027

Administrator's Signature: \_\_\_\_\_ 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023