

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016032
DATE: 12/13/2023
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Custom Clad" Aluminum Clad Wood Double Hung Window (w/Nail Fin & Masonry Strap) Configuration: X/X Glazing: Monolithic (Annealed) Frame: W-1245mm(49.38") H-2445mm(96.25") Sash: W-1181mm(46.50") H-1210mm(47.63") DLO: W-1102mm(43.38") H-1102mm(43.38")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class LC-PG25 1254 x 2445 (49 x 96)-H Design Pressure: 1200 Pa (25 psf) Positive Design Pressure: 1200 Pa (25 psf) Negative Design Pressure: 1440 Pa (30 psf) Water Penetration Resistance Test: 260 Pa (5.43 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Intertek, PLC
Report No: H0418.04-301-47
Expiration Date: December 31, 2027

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023